

ENFORCEMENT NOTICE

Notice No: ESFRS/HA/MH/0912/E1/23

Notice requiring steps to be taken under Article 30 of the Regulatory Reform (Fire Safety)
Order 2005

Name of Premises: The Pig

Address of Premises: 37, White Rock, Hastings, TN34 1JL.

Responsible Person: Broken Unicorn Promotions Ltd

I, are on behalf of East Sussex Fire Authority, hereby give you notice that the Fire Authority are of the opinion that, as a person being under an obligation to do so, you have failed to comply with the requirements placed upon you by the Regulatory Reform (Fire Safety) Order 2005 in respect of the above named premises and the persons who may be on the premises or who may be affected by a fire on the premises.

The matters which, in the opinion of the Fire Authority, constitute the failures to comply with the Regulatory Reform (Fire Safety) Order 2005 are specified in the Schedule to this Notice.

The Fire Authority is further of the opinion that the steps identified in the Schedule to this Notice must be taken to remedy the specified failures to comply with the Regulatory Reform (Fire Safety) Order 2005.

The steps identified in the Schedule are to be completed by the dates indicated.

Unless the steps identified in the Schedule to this Notice have been completed within the given time limit, you will be deemed not to have complied with this Notice and the Fire Authority may consider a prosecution against you. You may however apply for an extension to this time limit (see notes).

You have the right to appeal against the Notice (see notes), by way of complaint for an order, to the Clerk to the Court of the Magistrates' Court acting for the petty sessions area in which your premises is located. If you wish to bring an appeal, you must do so within 21 days of the date this Notice is served on you. The Magistrates' Courts Act 1980 will apply to the proceedings. The bringing of an appeal shall have the effect of suspending the operation of this Enforcement Notice until the appeal is finally disposed of or, if the appeal is withdrawn, until the withdrawal of the appeal.

Signature

Date: 12 September 2023

(on behalf of, and duly authorised by, East Sussex Fire Authority)

SCHEDULE REFERRED TO IN ENFORCEMENT NOTICE NO ESFRS/HA/MH/0912/E1/23 REQUIRING STEPS TO BE TAKEN UNDER ARTICLE 30 OF THE REGULATORY REFORM (FIRE SAFETY) ORDER 2005 ISSUED BY EAST SUSSEX FIRE AUTHORITY ON 12 SEPTEMBER 2023.

Name of Premises: The Pig

Address of Premises: 37, White Rock, Hastings, TN34 1JL

Where appropriate, a plan may form part of this Schedule to illustrate the steps which, in the opinion of the Fire Authority, need to be taken in order to comply with the Regulatory Reform (Fire Safety) Order 2005.

<u>Note:</u> Notwithstanding any consultation undertaken by the Fire Authority, **before** you make any alterations to the premises, **you** may need to apply for approval from either the Local Authority Building Control or an Approved Inspector and/or the approval of any other local bodies having a statutory interest in the premises.

SCHEDULE

The location and details of matters which are considered to be failures to comply with the Regulatory Reform (Fire Safety) Order 2005 are detailed, along with the steps considered necessary to remedy the failures.

Failure under Article 8(1)(a) & 8(1)(b) of the Regulatory Reform (Fire Safety) Order 2005. (The responsible person must take such general fire precautions as will ensure the safety of all persons present).

1.1 Failure

The Responsible Person has failed to take measures to reduce the risk of the spread of fire and smoke throughout the premises.

Remedy

Carry out a survey to verify compartmentation between floors and adjoining premises, especially those premises located above and where necessary, carry out work to improve compartmentation to an appropriate standard in accordance with published HM Government guidance.

DATE REQUIRED - 18 March 2024

Supporting Information

Subject to the findings of your Fire Risk Assessment, it may be acceptable to use appropriate automatic fire detection and alarms to compensate for any deficiencies in compartmentation so as to reach an acceptable overall level of safety from fire. Where this involves other premises outside of your control, you should cooperate and coordinate with other relevant Responsible Persons as required.

2 Failure under Article 11(1) and 11(2) of the Regulatory Reform (Fire Safety) Order 2005. (The responsible person must make and give effect to appropriate arrangements for the effective planning, organisation, control, monitoring and review of the preventative and protective measures).

2.1 Failure

The responsible person has failed to make and give effect to appropriate fire safety arrangements relating to the fire precautions within the premises.

Remedy

The responsible person should make and give effect to appropriate fire safety arrangements relating to the fire precautions within the premises.

DATE REQUIRED - 16 October 2023

Supporting Information

Such arrangements should show what is to be done, who is responsible for ensuring that it is done and when it is scheduled to take place. In making and giving effect to such arrangements, the following matters should be considered:

- Has a senior manager within the organisation been appointed to take responsibility for all matters relating to fire safety?
- Have other managers been delegated fire safety duties relevant to their role?
- Has a fire risk assessment been planned, completed, reviewed, etc.?
- Has staff training (including induction and refresher training) been scheduled?
- Have fire drills been planned and scheduled?
- Has appropriate equipment maintenance been scheduled and booked?
- Is there appropriate cooperation and coordination with other Responsible Persons?
- Are all of the above matters written-in to a fire safety policy document?

Failure under Article 13(1)(a) of the Regulatory Reform (Fire Safety) Order 2005. (The responsible person must ensure that the premises are equipped with appropriate firefighting equipment and with fire detectors and alarms).

3.1 Failure

The responsible person has failed to ensure that the premises is fitted with an appropriate fire alarm and warning system.

Remedy

Install a suitable fire detection and alarm system within the premises so as to comply with the standard detailed in the appropriate HM Government Guide. The fire alarm system should comply with BS 5839: Part 1 or equivalent.

In the Fire Authority's opinion, a BS 5839: Part 1: Category L2 System would be appropriate.

DATE REQUIRED - 18 March 2024

Supporting Information

Subject to confirmation in your Fire Risk Assessment, and in order to avoid false alarms caused by potential malicious operation of call points by members of the public, it would be acceptable to site call points behind the bar. In addition, to avoid false alarms caused by smoke generators during live events, it would be acceptable to fit heat detectors in those areas likely to be affected.

Failure under Article 14(2)(b) of the Regulatory Reform (Fire Safety) Order 2005. (The responsible person must ensure that, in the event of danger, it is possible for persons to evacuate the premises quickly and safely).

4.1 Failure

The responsible person has failed to ensure that sliding doors are not used as emergency exits from the premises.

Remedy

Change the sliding door on the exit route through the adjoining premises, currently the Crime Museum, to a conventional outward opening door. If this cannot be agreed by the Crime Museum, ensure the sliding door is opened at all times when this route is required (I.e. evening opening of The Pig when the Crime Museum is closed).

DATE REQUIRED - 16 October 2023

4.2 Failure

The inward opening final exit door from the Crime Museum is fitted with an opening device (thumb turn) that could cause confusion and is not suitable for large numbers of members of the public I.e. more than 60 persons.

Remedy

Install suitable signage adjacent to the thumb turn indicating that it should be turned to open with the direction of opening shown.

DATE REQUIRED - 16 October 2023

Supporting Information

You should also train staff to immediately attend this route in case of an emergency to open the door before the public arrive at it.

4.3 Failure

The emergency exit doors from the rear function room and main bar area, are not fitted with opening devices suitable for large numbers of members of the public i.e. over 60 persons.

Remedy

Install emergency push bars to all outward opening exit doors

DATE REQUIRED - 16 October 2023

Supporting Information

Push pads are only suitable for small numbers of staff.

Failure under Article 17 of the Regulatory Reform (Fire Safety) Order 2005. (The responsible person must ensure that any facilities, equipment and devices provided in relation to fire safety matters within the premises are maintained in an efficient state, in efficient working order and in good repair).

5.1 Failure

The Responsible Person has failed to ensure that the rear external fire escape route is properly maintained, as there is an unprotected edge and also evidence of corrosion supported by temporary scaffolding.

Remedy

Make arrangements to ensure the unprotected edge is made safe and that the structural integrity of the escape route is verified and maintained.

DATE REQUIRED - 16 October 2023

Supporting Information

This may be a matter that will need addressing by other persons with responsibility at the premises as this is a shared escape route. BS 8210 highlights that a structural check of an external metal fire escape should be carried out every 5 years.

Failure under Article 22 of the Regulatory Reform (Fire Safety) Order 2005. (Where two or more responsible persons share or have duties in respect of premises, each such person must co-operate with the other responsible person concerned so far as is necessary to enable them to comply with the requirements and prohibitions imposed on them by or under the Order).

6.1 Failure

The Responsible Person has failed to co-operate and co-ordinate their activities with other responsible persons with whom they share the premises.

Remedy

The Responsible Person must co-operate and co-ordinate with other responsible persons who share the premises or the building to ensure that they inform the other responsible persons concerned of the risks to relevant persons arising out of or in connection with the conduct by him/her of his/her undertaking.

DATE REQUIRED - 16 October 2023

The Fire Authority considers that the above detailed steps will reduce the excessive risk to an acceptable level in the premises. Alternative ways of achieving an equivalent standard may be available and any request for the Fire Authority to consider alternative proposals should be submitted as a matter of urgency.

NOTES TO ACCOMPANY ENFORCEMENT NOTICE SERVED UNDER ARTICLE 30 OF THE REGULATORY REFORM (FIRE SAFETY) ORDER 2005

- 1. Contravention of any requirement imposed by an Enforcement Notice is an offence under Article 32 of the Regulatory Reform (Fire Safety) Order 2005 and renders the offender liable, on summary conviction, to a fine not exceeding the statutory maximum or, on conviction on indictment, to an unlimited fine, or imprisonment for a term not exceeding two years, or both.
- 2. In any proceedings for an offence referred to in Note 1, where the commission by any person of an offence under the Order is due to the act or default of some other person, that person is guilty of the offence, and a person may be charged with and convicted of the offence whether or not proceedings are taken against the first mentioned person.
- 3. Nothing in the Order operates so as to afford an employer a defence in any criminal proceedings for a contravention of those provisions by reason of any act or default of an employee or person nominated to implement measures for fire-fighting and procedures for serious and imminent danger and for danger areas, and appointed to assist him/her in undertaking such preventive and protective measures as necessary.
- 4. Subject to Note 3, in any proceedings for an offence under the Order, except for a failure to comply with articles 8(a) (Duty to take general fire precautions) or 12 (Elimination or reduction of risks from dangerous substances), it is a defence for the person charged to prove that he/she took all reasonable precautions and exercised due diligence to avoid the commission of such an offence.
- 5. In any proceedings for an offence under the Order consisting of a failure to comply with a duty or requirement so far as is reasonably practicable, it is for the accused to prove that it was not reasonably practicable to do more than was in fact done to satisfy the duty or requirement.
- 6. A person on whom an Enforcement Notice is served may under Article 35 of the Order appeal to the Magistrates' Court within 21 days from the date on which the Enforcement Notice was served. The bringing of an appeal has the effect of suspending the operation of the Notice until the appeal is finally disposed of or, if the appeal is withdrawn, until the withdrawal of the appeal.
- 7. The Fire Authority may grant, at their discretion, an extension (or further extension) of time specified for the steps to be taken if an appeal against the Notice is not pending. Application for an extension of time should be addressed to the above named Officer.
- 8. If you are the responsible person you are under an obligation to comply with the provisions of the Order or of any regulations made under it. If you have failed to comply and you and the Fire Authority cannot agree on the measures that are necessary to remedy the failure(s), the question may be referred to the Secretary of State for his determination under Article 36 of the Order.
- 9. To satisfy the 'Environment and Safety Information Act 1988' the Fire Authority is obliged to enter details of this Enforcement Notice into a register to which the public have access. If you feel that any such entry would disclose secret or confidential trade or manufacturing information, then you should appeal in writing to the Authority within a period of fourteen days following; a) the day on which the appeal period in Note 6 above expires, or b) the day on which the appeal is finally disposed of, where an appeal is brought. The following summary of the contents of the Notice will be entered on the public register: -

Served On	Notice Type	Premises Name	Location	Notice Number
12 September 2023	Enforcement	The Pig	Hastings	ESFRS/HA/MH/0912 /E1/23

The Public Register can be accessed via the internet at **www.esfrs.org** and this actual notice may be viewed by clicking on the link shown in the table above.

- 10. The works or actions specified in the Notice are only intended to ensure a satisfactory standard of fire precautions that will comply with the Order. The Notice is issued without prejudice to any other enforcement action that may be taken by this, or any other, enforcing authority.
- 11. The Fire Authority would be willing to consider and reasonably assist with any proposals you may have to remedy the matters specified in the Notice.
- 12. To assist with administration procedures, it would be helpful if you could quote the reference number (at the top of this Notice) when dealing with the Fire Authority.